

Pomieszczenia

Symbol Pomieszczenia	θ_i [°C]	Liczba grzejników	Φ [W]	Φ_{wym} [W]	Φ_{op} [W]	Φ_{grz} [W]	Wynik. Φ_{op} [W]	Wynik. Φ_{grz} [W]	Wynik. Φ_{dz} [W]	Pokrycie strat [%]
-------------------------	--------------------	----------------------	---------------	---------------------	--------------------	---------------------	------------------------------	-------------------------------	------------------------------	--------------------------

Kondygnacja 0, Rzędna 0,0m, Jednostka budynku 01

0.01	20	2 k	0	2013	0	2013	0	8013	0	398
0.03	20	4 k	0	7960	0	7960	0	7960	0	100
0.03	20	1 k	0	265	0	265	0	265	0	100
0.04	20	1 k	0	956	0	956	0	956	0	100
0.05	20	1 k	0	339	0	339	0	339	0	100
0.06	20	1 k	0	625	0	625	0	625	0	100
0.07	20	2 k	0	1246	0	1246	0	1246	0	100
0.08	20	2 k	0	1510	0	1510	0	1510	0	100
0.09	20	1 k	0	208	0	208	0	208	0	100
0.10	20	1 k	0	545	0	545	0	545	0	100
0.11	20	1 k	0	983	0	983	0	983	0	100
0.12	20	1 k	0	419	0	419	0	419	0	100
0.13	24	3 k	0	2184	0	2184	0	2184	0	100